

**CITY OF FERNDALE  
THORNTON ROAD WATER PUMP STATION UPGRADE**

**ADDENDUM NO. 5 (1 page total)  
Issue Date: May 31, 2018**

General: Recitations of each and every section of the bid documents impacted by this addendum are not given. The described changes impact all relevant portions of the bid documents whether specifically cited below or not.

**SECTION 16925 – INSTRUMENTATION AND CONTROL, 2.4, A.:**

Add the following requirements for the specified electromagnetic flow meter:

1. Web server for verification cert printout & configuration of meter
2. Integrated data logger
3. Ethernet/IP available with Add-on-Profiles for seamless integration with Rockwell PLC's