

**CITY OF FERNDALE
SHOP WELL #2 PERMANENT PUMP PROJECT**

**ADDENDUM NO. 1 (2 pages total)
Issue Date: July 16, 2020**

General: Recitations of each and every section of the bid documents impacted by this addendum are not given. The described changes impact all relevant portions of the bid documents whether specifically cited below or not.

PART 1 – BIDDING REQUIREMENTS

SECTION 00 41 00 – BID PROPOSAL:

List of Manufacturers: Add Goulds (Goulds Water Technology) to the Base Bid Manufacturer list for permanent well pump equipment. Replace page 2 of 3 with attached.

Clarification: Both the specified Peerless pump and the comparable Goulds pump are to be named manufacturers. Based on our research, the comparable Goulds pump model is VIS-WFTM 8FDLC, 8 stages with a 200 HP Tesla TR10 motor. All wetted parts are to be either 316SS or 316LSS. In addition, please note that the submersible deep well turbine water pump must be able to operate with pump efficiency values of 62% to 75% (or greater) throughout a 400 gpm to 960 gpm operation range at full speed (60 Hz).

ATTACHMENTS:

- Section 00 41 00 – Bid Proposal (Page 2 of 3)

LIST OF MANUFACTURERS

The named manufacturers for some equipment items are listed below. Contractor is to circle their selected manufacturer, when a choice is available. Contractor's Base Bid Item #1 – Wellhouse Project is to be based on the following:

<u>Equipment</u>	<u>Base Bid Manufacturer</u>
A. Permanent Well Pump	<u>Peerless, Goulds</u>

EQUIPMENT ALTERNATES:

Contractors may submit an approval package for equipment of alternate manufacturers to the base bid manufacturer for review with their bid and included as an Equipment Alternate on this Bid Proposal. A pre-approval review prior to bid will not be done. Contractors proposing alternate manufacturers will be responsible for all costs associated with system evaluation and redesign including all electrical, mechanical, and civil aspects of the installation.

- A. Furnish Permanent Well Pump Equipment other than specified.
 Lump Sum Deduction \$ - Deduction _____
 Amount in Words: _____
 Manufacturer & Model No. _____

Note 1: Mobilization items and partial payments for Mobilization shall be in accordance with WSDOT Standard Specifications Section 1-09.7.

Note 2: See Section 00 24 13 –Scopes of Bids for more description of each bid item.

The Owner reserves the right to accept or reject any or all bid prices within sixty (60) days of the bid date.

Time for Completion

See Supplementary Condition 15 - Completion Date for completion time requirements.

Liquidated Damages

The undersigned agrees to pay the Owner as liquidated damages the sum as specified in the General Conditions for each consecutive calendar day that is in default after the Contract Time. Liquidated damages shall be deducted from the contract by change order or from the Contractor's application for payment as determined by Owner in its sole discretion.

Contractor is required to pay Washington State Prevailing Wages. All work performed on this project will be subject to the prevailing state wage rates.