

**CITY OF FERNDALE  
SHOP WELL #2 PERMANENT PUMP PROJECT**

**ADDENDUM NO. 4 (1 page total)  
Issue Date: July 28, 2020**

General: Recitations of each and every section of the bid documents impacted by this addendum are not given. The described changes impact all relevant portions of the bid documents whether specifically cited below or not.

**PART 2 – CONTRACTING REQUIREMENTS**

SECTION 00 73 00 – SUPPLEMENTARY CONDITIONS, 12. SUBCONTRACTING

**Adjust the following sentence:** The Contractor shall perform work amounting to a minimum of 5% (not 50%) of the Awarded Contract Price using his own personnel and equipment.

Clarification: General Contractors may plan to subcontract pump removal/installation work, as needed.

**PART 3 – TECHNICAL SPECIFICATIONS**

SECTION 43 25 00 – WELL PUMP, 2.0 MATERIALS, Motor

**Add the following:** The Tesla model TR10 motor and the Franklin model 2391086204 motor have both been reviewed and approved for this application. As specified, motor is to be rated for 200 HP and all wetted parts are to be either 316SS or 316LSS. In addition, motor will be started with a variable frequency drive, and is to be suitable for use with a VFD. It is anticipated that motor will be supplied with a three lead configuration.

**\*\*\* END OF ADDENDUM \*\*\***